



Utility Grade Protection Relay may not be required if Induction Generator is inverter based and Certified to UL1741 & IEEE C62.41 and C62.45"

INDUCTION GENERATOR
 VAC ____
 kW ____
 Three (3) Phase

Three (3) phase Generator
 One-Line Diagram 01/30/2012

* Note: Dashed items if Applicable depending on the design

TITLE BLOCK
 - Customer Name
 - Address of the installation
 - Date of Drawing
 - REV #
 - PE. Stamp
 - ELECTRICAL THREE LINE DRAWING